

**WARNING:** The function of this valve is demanding on the compression system and requires extra care. Always tighten nut to specified torque and if using a tighten to stop fitting always tighten the nut to the stop. Some copper tubes are sized to spec at each end of the pipe, but reduced to a smaller diameter throughout most of the roll. Always verify the tube diameter is in spec, use rounding tools. Out of spec and out of round tube will reduce the effectiveness of compression fittings. **Improper installation can result in the failure of the gripping mechanism allowing the valve to become disengaged from the tubing and act like a projectile causing injury or death.**



**WARNING:** Beginning January 1, 2010, it is unlawful in **CALIFORNIA** and **VERMONT** to use any product in the installation or repair of any public water system or any plumbing in a facility or system that provides water for human consumption if the wetted surface area of the product has a weighted average lead content greater than 0.25%. This prohibition does not extend to service saddles used in the state of **CALIFORNIA**.

## **A. Y. McDonald Mfg. Co.**

P.O. BOX 508 • DUBUQUE, IA 52004-0508  
800-292-2737 • FAX 800-832-9296