
## SUBMITTAL DATA SHEET

NL Service Fitting –  $708U2M 1 \times 3/4 \times 6.5$ 

-22 CTS Compression x MNPT





## SUBMITTAL INFORMATION

- Manufactured in compliance with ANSI/AWWA C800 (latest revision)
- Brass components in contact with potable water conform to ASTM B584, UNS C89833 (latest revision) and identified with "NL"
- Certified to NSF/ANSI 61 and NSF/ANSI 372
- Brass components not in contact with potable water conform to ASTM B62 and ASTM B584, UNS C83600 -85-5-5-5 (latest revision)
- Large wrench flats provided for proper installation
- Insert stiffeners required on all flexible plastic connections



**A.Y. McDonald Mfg. Co.** 4800 Chavenelle Rd Dubuque, IA 52002

**Toll Free:** 1-800-292-2737 sales@aymcdonald.com

aymcdonald.com

A.Y. McDonald considers the information on this assembly drawing correct when published. Item and option availability, including specifications, are subject to change without notice.

Submitted by: 10-14